



January 15, 2013

Mr. Steve Weddle  
National Sales Manager  
Innovative Building Products, Inc.  
3024 Acme Brick Plaza  
Fort Worth, TX 76109

Dear Mr. Weddle:

On behalf of the National Floor Safety Institute I would like to thank you for submitting your product for Phase 1 testing. IBP GlassWalk Floor System was tested per the ANSI/NFSI B101.1-2009 Test Method for Measuring Wet SCOF of Common Hard-Surface Floor Materials on January 11, 2013 and the average Static Coefficient of Friction was 0.78 which exceeds our minimum acceptable wet SCOF value of a 0.6 and is therefore eligible for Phase 2 testing on walkway surfaces.

The purpose of the ANSI/NFSI B101.1-2009 is to determine the wet Static Coefficient Of Friction (SCOF) of hard surfaced flooring materials (ie: ceramic floor tile, vinyl floor coverings, finishes, etc.) using the BOT-3000. The product was tested per Phase 1 of our certification process and does not reflect real-world performance as evaluated in Phase 2 testing therefore the product is not NFSI Certified.

Please feel free to contact us if you have any questions. Thank you.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Russell J. Kendzior', is written over a horizontal blue line.

Russell J. Kendzior  
President